

SECTION 11

11.07 DETERMINATION TO USE NONPOTABLE WATER:

Denver Water shall determine whether a given service will be furnished with nonpotable water or potable water. The determination shall be in accordance with the standards of treatment and water quality requirements set forth in the regulations promulgated by the State of Colorado. The intent of Denver Water is to protect public health while giving consideration to the availability and/or feasibility of providing nonpotable water.

If nonpotable water is available and Denver Water determines that it is feasible to supply nonpotable water for a specified use, the user must use the nonpotable water. Denver Water will make the decision where nonpotable water is to be used.

If nonpotable water is not immediately available for use when the design area is ready for construction, and if Denver Water has determined that nonpotable will be supplied in the future, the on-site facilities shall be designated to use nonpotable water. The on-site nonpotable system shall be designed and constructed to Denver Water's construction specifications as set forth herein. Provisions shall be made, as directed by Denver Water, and these specifications followed to allow for connection to the nonpotable water system when nonpotable water is available. In the interim, potable water will be supplied to the nonpotable water system through a temporary potable water connection installed by Denver Water. An approved backflow prevention device will be required on each nonpotable service line or distribution main as long as potable water is supplied. The backflow prevention device shall be located downstream of the meter and become a part of the on-site facilities.